

**Demo Door Co.**

345 West Industrial Road

Anytown, USA 58466

p:(555) 555-5555 | f:(555) 444-4444

service@demodoorco.com

**Door - PM Inspection**

Report Date Apr 01, 2015 11:16 MDT

*This report summarizes inspection results including grades, notes and photographs.*

Customer:	<b>Darrien Welding &amp; Grinding</b>	Building:	<b>Main Fab Shop</b>
Address	9503 - 45 Avenue, Tucson, AZ, US - 84596		
Contact 1:	John Anderson	Contact 2:	Rhonda Paige
Phone:	805-555-4588	Phone:	805-652-3655
Email:	john@dbf.com	Email:	rhonda@dbf.com

Door ID & Description
Door ID <b>0001722</b>
Description PUR 9' x 10' E/O

Inspection Date/Time ID			
Created	<b>Feb 24, 2015</b>	14:43	Not SafedoorPM Compliant
Finished	Feb 24, 2015	14:50	Not Posted
Signature			

Door Notes	Shipping door 1
------------	-----------------

DOOR			
GRADE	INSPECTION ELEMENT	NOTES	PHOTO
Fail	Cables, cable anchors, bottom brackets	[2015-02-24 14:45] FW: Cables twisting	YES (1)
Pass	Rollers, roller brackets, end framing, center hinges		
Pass	Struts, span braces		
Pass	Vertical track, brackets		
Pass	Sections, joints, gaskets	[2015-02-24 14:46] FW: Bottom panel creased	YES (1)
Pass	Windows, glazing		
Fail	Shaft, couplers, drums	[2015-02-24 14:50] FW: LHS drum worn D850-132	YES (1)
Pass	Bearings, bearing plates		
Pass	Torsion springs		
Pass	Pusher springs, bumpers, stops		
Fail	Door level, balance	[2015-02-24 14:47] FW: Door heavy	
Pass	Weatherstrip, U-rubber, top flap		
Pass	Door safety labeling		
Pass	Door operation		

**Demo Door Co.**

345 West Industrial Road

Anytown, USA 58466

p:(555) 555-5555 | f:(555) 444-4444

service@demodoorco.com



**Door - PM Inspection**

Report Date Apr 01, 2015 11:16 MDT

*This report summarizes inspection results including grades, notes and photographs.*

OPERATOR			
GRADE	INSPECTION ELEMENT	NOTES	PHOTO
Pass	Operator mounting and anchoring		
Pass	Spreader bar		
Pass	Drive gear		
Pass	Clutch (force), brake		
Pass	Limits		
Pass	Electrical, enclosure		
Pass	Manual release, emergency chain hoist		
Pass	Operator safety labeling	[2015-02-24 14:48] CW: Installed entrapment warning placard	
Pass	Wall control station		
Pass	Sensing edge - primary		
Pass	Interlock		YES (1)

PHOTOS					
					
0001722	Cables, cable anchors, bottom brackets	0001722	Sections, joints, gaskets	0001722	Shaft, couplers, drums
					
0001722	Interlock				